Public Record – Summary Information For Regulated Underground Storage Tanks (USTs) Nevada Division of Environmental Protection (NDEP)

Date Posted To Web: February 10, 2025

General Information:

Total Number of UST Facilities: 1,352

Total Number of USTs: 4,056

Summary of Information For On-Site Inspections:

Number of UST Facilities Inspected: 1086

Inspection Period Dates: October 1, 2023 through September 30, 2024

Percent Compliance (TCR Combined measure): 24%

Note: The above tank and facility numbers were produced from NDEP's Database. Compliance inspections are conducted by NDEP staff in rural counties, the Southern Nevada Health District staff in Clark County, and the Northern Nevada Public Health staff in Washoe County.

Please click on the following link for each UST implementing agency's contact information: http://ndep.nv.gov/bca/file/contacts 0608.pdf

Summary Information for Releases:

Number of Confirmed Releases: 16 (At 15 UST Facilities)

Release Reporting Period Dates: October 1, 2023 through September 30, 2024

Summary Information For Release Sources And Causes:

Source			Spill		Overfill		Phys/Mech Damage **		Corrosion		Install Problem		Other		Unknown	
	#	%	#	%	#	%	#	%	#	%	#	%	#	%	#	%
Tank	12	75%	0	0%	0	0%	0	0%	0	0%	0	0%	12	100%	0	0%
Piping	3	19%	0	0%	0	0%	3	100%	0	0%	0	0%	0	0%	0	0%
Dispenser	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%
STP *	0	0%	0	0%	0	0%	3	0%	0	0%	0	0%	0	0%	0	0%
Delivery Problem	0	0%	0	0%	1	0%	0	0%	0	0%	0	0%	0	0%	0	0%
Other	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%
Unknown	1	6%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	1	100%
Totals	16	100%	0	0%	1	6%	6	38%	0	0%	0	0%	12	75%	1	6%

^{(# =} Number; Source % = Percent of source total number; Cause % = Percent of individual source (i.e. spill, overfill, etc.))

Note: Release source/causes data for the referenced reporting period were collected using NDEP's Project Tracking (PT) database and Nevada Petroleum Fund coverage applications.

Please click on the following link for NDEP database information and LUST file review procedures: http://ndep.nv.gov/admin/env_info_request.htm

^{*} STP = Submersible turbine pump/sump area; ** Physical/Mechanical Damage